NEW JERSEY OF NEWARK,

SEE VALVE BOX DETAIL

WRENCH NUT - 2" SQUARE TURN -CLOCKWISE TO OPEN 8" MIN, — VALVE BOX SHOULD BEAR ON EARTH -AND NOT DIRECTLY ON THE VALVE MECHANICAL JOINT WITH RETAINER GLANDS FLEXIBLE TRANSITION -(MEGA LUGS) COUPLING (TYP) RESTRAINING RODS (TYP) SEE STRAPPING DETAIL CLASS 350 FRICTION CLAMP D.I.P. SPOOL EXISTING MAIN PIECE RESTRAINING RODS TO TEE (USE BELL CLAMP FOR PUSH-ON JOINT, OR ROD THROUGH BOLT HOLES FOR MECHANICAL JOINT)

FINISH GRADE

CAST IRON VALVE BOX

TO BE SET PLUMB

NOTE:

NEWARK CITY MUST CONFIRM THAT A SHUT-DOWN CAN OCCUR BEFORE GATE VALVE REPLACEMENT