



NOTES:

1. INSTALLER MUST COMPLETE THE MOST UP TO DATE APPLICATION FORM FOR THE PHYSICAL CONNECTION PERMIT FROM NJDEP. THE FORM MUST BE COMPLETED BY THE BUILDING OWNER / DEVELOPER BEFORE INSTALLATION OF THE BACKFLOW PREVENTER.
2. FOR INSTALLATIONS LESS THAN 3"
3. EQUIPMENT TO BE INSTALLED AT A MINIMUM OF 24" FROM ANY STRUCTURES OR HARDSCAPING
4. WHEN UNIT IS NEXT TO A STRUCTURE MOUNT TEST CORKS ON OPEN OR NON STRUCTURE SIDE
5. ALL FITTINGS SHALL COMPLY WITH NEW JERSEY STATE REQUIREMENTS, AWWA STANDARDS, AND HEALTH AND SAFETY CODE (NO LEAD BRASS)

CREATED: 6-5-2023

WATER - DETAIL 47

CITY OF NEWARK, NEW JERSEY

DOUBLE CHECK VALVE

